



BOOSTER PUMP DETAILS

LOTS	HOME UNITS	PEAK HOUR CONSUMPTION (LTRS)	TOTAL PEAK CONSUMPTION (LTRS)	PUMP SETUP	PUMP CAPACITY (LTR/SEC)	PUMP SPEC
89	178	600	106,800	DUAL DUTY + STANDBY	(15 + 15) x 15	3 X CRE 15 GRUNDFOS HYDRO MPVC

COPYRIGHT
 THE CONCEPT AND INFORMATION CONTAINED IN THIS DOCUMENT ARE THE COPYRIGHT OF HOUSING AUTHORITY. NO PART OF THIS DOCUMENT IS TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, WITHOUT THE APPROVAL OF THE HOUSING AUTHORITY OF FIJI WILL CONSTITUTE INFRINGEMENT OF COPYRIGHT.

Housing Authority
 FIJI ISLANDS
 info@housing.com.fj

REV	DESCRIPTION	APPROVAL	ISSUE DATE	SURVEYOR
1	ISSUED FOR TENDER	A RAMUA	14 OCT 25	D PECKHAM
				D PECKHAM
				D PECKHAM

FOR TENDER
 ISSUED:
 APPROVER - GMLHD:
 A RAMUA

TITLE:
 TAVAKUBU ADDITIONAL CIVIL WORKS

DRAWING TITLE:
 PLAN
 PROPOSED WATERMAIN EXTENSION
 (SHEET 1)

SCALE:
 1 : 500 (A1)
 1 : 1000 (A3)
PROJECT NO:
 E565
SHEET:
 E565C400-PL-01-R1